



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: Ushers Ferry Lawyer House Holding Tank, RFB #PUR0216-152
Dated: February 22, 2016
Subject: Addendum #1 (1 page)
Date: February 29, 2016

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Change:** Holding tank shall be concrete; fiberglass units will not be accepted.
- 2) **Clarification:** The City will provide all interior plumbing for the restroom and will extend the pipe through the above ground crawl space at the rear of the house (southwest corner).
- 3) **Clarification:** Contractor can provide normal exterior lid on the holding tank; the City will landscape and camouflage the lid after completion of this project.
- 4) **Clarification:** Excess dirt shall be stockpiled by the Contractor in an area behind the dig site.
- 5) **Clarification:** The City will mark all known utilities.
- 6) **Clarification:** The City will remove a portion of the wooden sidewalk and trim any trees necessary to allow for Contractor to access the site.
- 7) **Clarification:** The holding tanks shall be installed at the south side of the house in front of the trees.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Monday, March 7, 2016, before 3:00 pm CST at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.