



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: Cottage Grove Lane Storm Sewer Improvements, RFB #PUR0416-180
Dated: April 19, 2016
Subject: Addendum #1 (1 page)
Date: April 26, 2016

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** We went to the site today and are wondering why the design doesn't go from the end of the grate to the manhole. With the grate being on an angle that stops a child from being swept down the manhole but it doesn't stop the kid from falling off the end of the grate and falling down into the channel of the storm line. Would we be able to get more info as to what they are trying to achieve?
Answer: The issue at this site is that the throat of the intake is routinely being clogged with debris. The intent of this project is to install a grate that will redirect debris over the manhole. The existing concrete flume has a grate overtop that already limits a person's access to the storm sewer system.
- 2) **Question:** Does the City of Cedar Rapids have easements alongside this storm water area or does the contractor need to communicate with the adjacent home owner?
Answer: As shown on Sheet D.01, there is an existing 20' wide storm sewer easement that will allow access to complete the work.
- 3) **Question:** Is a right of way permit required?
Answer: Yes, Contractor shall apply for a right of way permit, which is required for this project. This is a City project so the permit will be provided at no fee to the Contractor.
- 4) **Question:** Is a construction survey required?
Answer: A construction survey is not required if the Contractor does not deem it necessary to complete the Work. It will be the responsibility of the Contractor to ensure that all Work is completed within the designated right-of-way and storm sewer easement.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Tuesday, May 3, 2016, before 3:00 pm CDT at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.