



## ADDENDUM #1

**To:** All Companies Interested in Submitting a Bid  
**From:** Diane Muench, CPPB, Purchasing Agent  
**Bid:** 2016 Sidewalk Grinding, RFB #PUR0116-130 Dated: January 19, 2016  
**Subject:** Addendum #1 (1 page)  
**Date:** January 26, 2016

---

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** When the 3640 lineal feet was calculated, was it based on an average height of the tripping hazard? The less height would be cheaper per square lineal feet. Need to know what the 3640 lineal feet is based on.  
**Answer:** It is standard operating procedure for Public Works to request these grinds only when the tripping hazard (differential height between the sidewalk panels) was 1" or less, and greater than 1/4". Sidewalk shifts and recording differences are possible, making it possible for some of the tripping hazards to be greater than 1".
  
- 2) **Question:** Specification 4.3.1 shows a maximum tripping hazard height of 1-3/4". Is this the highest height for this project or are there potentially larger (up to 3") tripping hazard heights?  
**Answer:** There is a potential for some of the tripping hazards to be greater than 1-3/4", however is it unlikely.

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Wednesday, February 3, 2016, before 3:00 pm CST at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.