


**Click in box below to insert a picture**



**Intersection |** Street 1 or Address:

Street 2 or Address:

<b>Reference Image</b> (click in each box to the right to insert a picture)				
	Ramp Location <sup>1</sup>			
	Ramp Type? <sup>2</sup>			
	Yield or Stop? <sup>3</sup>			
	Located Midblock? <sup>4</sup>			
<b>Ramp Landing</b>				
Length (≥48") 60" <sup>5</sup>				
Width (≥48") 60" <sup>5</sup>				
Slope (≤2% in any direction)				
<b>Ramp (Perpendicular Ramp Standard Detail 2700-200)</b>				
Width (≥48")				
Length >15'?				
Run (perp., 5%-8.3%; blended, ≤5%)				
Cross (stop, ≤2%; yield, ≤5%)				
R Side Flare (if AR connects, ≤10%)				
L Side Flare (if AR connects, ≤10%)				
Grade Break Perp. to Ramp Run?				
Counter Run (≤5%)				
Counter Cross (if stop/yield, ≤2%; else, ≤5%)				

<b>Detectable Warning</b>				
Depth ( $\geq 24''$ )				
Width (=ramp width)				
Dome Height (=2'')				
Dome Size (base diameter, .9-1.4'; top diameter, 50-65% base diameter)				
Dome Spacing (1.6-2.4' b/w centers; >.65' b/w bases)				
<b>Sidewalk Extension (Parallel Ramp Standard Detail 2700-200)</b>				
Width ( $\geq 48''$ )				
Length >15'?				
Run ( $\leq 5\%$ )				
Cross ( $\leq 2\%$ )				

### Notes Section:

1. Each leg must be filled out.
2. *Select the appropriate curb ramp type:*  
Standard - See Standard Detail 2700-203  
Radial - See Standard Detail 2700-204  
Contiguous - See Standard Detail 2700-205
3. See Standard Detail 2700-200.
4. Provide property address (Street 1)
5. 60" required per City Specifications. Variances, on a case by case basis, may be granted and approved by the City Engineer or designee.

*Note:*

All sidewalk ramps shall meet current ADA Standards. See Standard Details 2700-200 through 2700-206 for all sidewalk ramp details.

For questions, contact [sidewalks@cedar-rapids.org](mailto:sidewalks@cedar-rapids.org)

---

### Additional Comments: