



NOTES:

1. ENTIRE ASSEMBLY, BELOW GRADE, SHALL BE WRAPPED WITH POLYETHYLENE SHEETING.
2. NEW MAIN MAY PASS ABOVE OR BELOW EXISTING MAIN BUT MUST MEET MINIMUM COVER REQUIREMENTS.
3. ALL JOINTS TO BE RESTRAINED PER METRO SPECIFICATIONS.
4. CONCRETE BLOCKING SHALL BE PER STANDARD DETAIL 2500-023.
5. ALL SYSTEM VALVES SHALL BE OPERATED BY JURISDICTION.
6. ALL TAPS 12-INCH AND SMALLER, SHALL BE PERFORMED BY CITY OF CEDAR RAPIDS.

FILE NO.: 2500-050	CEDAR RAPIDS METROPOLITAN AREA STANDARD DETAILS FOR PUBLIC IMPROVEMENTS	
APPROVAL DATE: JAN		
REVISION NO.: 1	"ROUND WAY" CONNECTION MAIN WITH TAPPING SLEEVE OR SADDLE	
REVISION DATE: JULY 2010		
	NO. 2500-050	