



## **ADDENDUM #1**

**To:** All Companies Interested in Submitting a Bid  
**From:** Heather Mell, Purchasing Agent  
**Bid:** Rough-In Plumbing-Ushers Ferry Lawyer House (Bid #PUR0316-169);  
Dated: June 14, 2016  
**Subject:** Addendum #1 (1 page)  
**Date:** June 17, 2016

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

### **Notes from Pre-Bid Meeting:**

- Contractor shall use Type A Pex underground from the curb stop
- Contractor shall tap the main
- Contractor shall use copper from main to curb stop
- City will hand dig and backfill.
- Contractor shall rough grade; City will do finish work
- City will remove fence on property where Contractor will be working
- Crawlspace interior hole will be dug by the City of Cedar Rapids City will open sheetrock and close wherever needed
- Specifications for fixtures will be provided to the awarded Contractor after award

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 20). The deadline for bid submittal is Friday, June 24, 2016 at 3:00pm CDT.