



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: Cedar Rapids Ice Arena ADA Compliance, RFB #PUR0716-010
Dated: July 29, 2016
Subject: Addendum #1 (1 page)
Date: August 4, 2016

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Information:** If the Contractor proposes to use new material (i.e., new handicap bathroom door), the architect would need to review and approve shop drawings. It is up to the Contractor if they wish to re-work the existing material or remove and install new.
- 2) **Information:** The budget for this project is \$120,000.
- 3) **Information:** For access to the Ice Arena, contact Dave Soper at (319) 560-8030. Dave will provide access for measurements, subcontractors, etc. but will not answer questions.
- 4) **Clarification:** Interior concrete work is part of the base project. Exterior concrete work is the alternate.
- 5) **Clarification:** The Ice Arena has extra chairs that can be used for companion chairs.
- 6) **Clarification:** Refer to Bid Package #2, detail 5/G1.3 and plan spec notes on G1.6, Division 9 Finishes, the contractor shall replace rubber flooring on ramp after the concrete slope has been modified with similar products by Mondo, Roppe or other commercial grade rubber floor manufacturer In the thickness and as close to the same color as the existing finish.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Thursday, August 11, 2016, before 3:00 pm CDT at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.