



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: F Avenue NW Transmission Main Repair, RFB #PUR0816-037
Dated: September 2, 2016
Subject: Addendum #1 (1 page)
Date: September 9, 2016

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** What is the engineer's estimate of cost?
Answer: The Engineer's Estimate is \$57,703.50. The Engineer's Estimate reflects the Owner will be supplying the following materials:
 - All water main required
 - All nitrile gaskets required
 - All valves required
 - All polywrap required
 - All tracer wire required
 - Fittings listed on Sheet C.2 of the plan set
 - Fire hydrant, water main, and fittings required for temporary flushing fire hydrant
 - 2) **Question:** Is a bid bond required?
Answer: No bid bond is required. Payment and performance bonds will be required from the awarded Contractor.
 - 3) **Question:** What are the start and finish dates?
Answer: Start Date: Upon approval of bonds and insurance. The Contractor shall notify ITC 3 weeks prior to the commencement of excavation required for replacement of the 24-inch butterfly valve located at STA 0+22.03, 7.94 R. Notification shall include expected duration of open trench. If high winds are expected (>20 mph), ITC requests construction be rescheduled to day with less wind. Contractor is allowed to start work on the 24-inch water main replacement at the Vinton Ditch and/or the valve replacement and valve installation north of the Vinton Ditch prior to notifying ITC.
Finish Date: Substantial completion of water main (in service) by 11/30/16
 - 4) **Question:** Is there a late completion penalty?
Answer: No, substantial completion of water main (in service) by 11/30/16.
 - 5) **Question:** Are there any liquidated damages?
Answer: No.
-

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Thursday, September 15, 2016, before 3:00 pm CDT at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.