



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Heather Mell, Purchasing Agent
Bid: Electrical Service-Noelridge Pole Barn (Bid #PUR1216-120); Dated: January 6, 2017
Subject: Addendum #1 (1 page)
Date: January 13, 2017

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Notes from the Pre-Bid Meeting:

- Contractor shall trench and run conduit underground. Alliant will run wire to meter located on building
- Will need a 40 amp breaker on the 220 outlet to run the compressor
- Contractor shall install switch for lights
- Contractor shall install emergency exit light above exit door
- Contract shall install a couple separate circuits for the general outlets
- Contract shall provide 24 circuits in the main panel
- City will flag for trenching location

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 20). The deadline for bid submittal is Thursday, January 19, 2017 at 3:00pm CST.
