



## **ADDENDUM #1**

**To:** All Companies Interested in Submitting a Bid  
**From:** Heather Mell, Purchasing Agent  
**Bid:** Overhead Doors-Noelridge Pole Barn (Bid #PUR1216-123); Dated: January 6, 2017  
**Subject:** Addendum #1 (1 page)  
**Date:** January 13, 2017

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

### **Notes from the Pre-Bid Meeting:**

- Contractor shall provide and install photo eye and push button. Does not need to be in conduit.
- Keyless entry shall be able to open both doors
- Door Color: White
- No windows
- Heavy duty springs – 50k cycle
- R-value on door shall be 17
- ½ horsepower minimum on the openers

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 20). The deadline for bid submittal is Thursday, January 19, 2017 at 3:00pm CST.

---