



ADDENDUM #2

To: All Companies Interested in Submitting a Bid
From: Rebecca Johnson, CPPB, Purchasing Agent
Bid: Vent Hood for Weld Booth (RFB #PUR1016-091); Dated: November 30, 2016
Subject: Addendum #2 (1 page)
Date: December 9, 2016

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Clarifications from pre-bid meeting held December 9, 2016:

- Exhaust motor shall be mounted through north wall with exhaust exiting through east exterior wall
- An additional drawing showing the weld exhaust vent is provided with this Addendum as Attachment E to the RFP
- Power source is located on the north wall on the other side of the west wall of welding bay
- All vehicles will be moved out of the way by City staff prior to commencement of work by the Contractor
- When cutting holes through wall panels Contractor shall avoid cutting through any joints and center the holes in the panels

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment C). The deadline for bid submittal is Friday, December 16, 2016 before 3:00 p.m. CDT.
