



### **ADDENDUM #1**

**To:** All Companies Interested in Submitting a Bid  
**From:** Heather Mell, Purchasing Agent  
**Bid:** Replacement Doors (Bid #PUR0417-216); Dated: May 8, 2017  
**Subject:** Addendum #1 (1 page)  
**Date:** May 15, 2017

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

#### **Notes from Pre-Bid Meeting:**

- Contractor shall perform work between 7:00-3:30 Monday-Friday.
- Fiberglass Reinforced Plastic (FRP) frame shall be provided if available in rough opening size. If FRP is not available, Hollow Metal Frame is acceptable. Frame shall have an industrial coating on inside and outside.
- All doors are passage doors, no locks needed.
- Contractor shall bring doors up to code if required.

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 21). The deadline for bid submittal is Monday, May 22, 2017 at 3:00pm CDT.

---