



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: Bever Park Maintenance Shop Masonry Repairs, RFB #PUR0517-224
Dated: May 8, 2017
Subject: Addendum #1 (1 page)
Date: May 16, 2017

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Clarification:** No block or brick shall be painted; only steel lintels are painted.
- 2) **Clarification:** Contractor shall power wash or grind out only the joints that need repair in the block. All brick shall be power washed.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Monday, May 22, 2017, before 3:00 pm CDT at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.