



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: Police Station & Shooting Range ADA Compliance, RFB #PUR0717-002
Dated: July 26, 2017
Subject: Addendum #1 (1 page)
Date: August 7, 2017

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Information:** Unless otherwise specified, the contractor shall install all paved surfaces following the city's designated standards for maximum slopes. This shall include 1.5% for cross slopes, 4.5% for running slopes, and 7.5% for any ramps. (G0.00)
- 2) **Information:** Detectable warning strips have been removed from the top of exterior ramps. (G3.01, G3.04)
- 3) **Information:** Detectable curb ramp warnings have been moved to bottom of curb ramp. (G3.01)
- 4) **Information:** Change in level transition strip detail has been altered to have rounded end rather than beveled. (G3.01, G3.04)
- 5) **Information:** The ADA signs shall be mounted such that they are 60" min to bottom of sign. (G3.01)
- 6) **Information:** Further information about specifics of braille on ADA entrance signs added to detail. (G3.01)
- 7) **Information:** Change in level transition strip and threshold has max ¼" change in level in its entirety. (G3.02)
- 8) **Information:** Further information regarding shower seat and controls location included in details 7 and 10. This information is also provided in ADA standards seats. (G3.03)
- 9) **Information:** Revised sheets are attached.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Wednesday, August 16, 2017, before 11:00 am CDT at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.