



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Heather Mell, Purchasing Agent
Bid: Overhead Doors-Noelridge Greenhouse Storage Garage (Bid #PUR0717-005); Dated:
July 21, 2017
Subject: Addendum #1 (1 page)
Date: July 28, 2017

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Notes from the Pre-Bid Meeting:

- Contractor shall provide and install photo eye and push button. Does not need to be in conduit.
- Door Color: White
- No windows
- Light Duty Commercial Opener – MT50
- R-value on door shall be between 17-18
- 8' xx 7' door shall have interior lock

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 20). The deadline for bid submittal is Thursday, August 3, 2017 at 3:00pm CDT.
