



## ADDENDUM #1

**To:** All Companies Interested in Submitting a Bid  
**From:** Rebecca Johnson, CPPB, Purchasing Agent  
**Bid:** HVAC Units for Veterans Memorial Stadium (RFB #PUR0817-029); Dated: 8/16/2017  
**Subject:** Addendum #1 (1 page)  
**Date:** August 25, 2017

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Clarifications from pre-bid meeting held Thursday, August 24, 2017:

- Existing HVAC units are all split units.
- New units will be installed in the same places as current units.
- The awarded contractor will be responsible for all electrical work required to complete the project.
- Units shall be both A/C and heat but are primarily used for A/C.
- Existing Carrier HVAC model numbers are:  

1-ton system, outside unit:	38BK018331
1-ton system, inside unit:	40QNH018320
1.5-ton system, outside unit:	38BK012320
1.5-ton system, inside unit:	40QNH012300

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment C). The deadline for bid submittal is Wednesday, August 30, 2017 before 3:00 p.m. CDT.