



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Heather Mell, Purchasing Agent
Bid: Caulking & Painting of Bever Pool and Slides (Bid #PUR0917-046);
Dated: November 21, 2017
Subject: Addendum #1 (1 page)
Date: November 29, 2017

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Notes from the Pre-Bid Meeting:

- New concrete is not included in this project.
- The expansion joint from the deck to the zero depth entry is included and shall be replaced.
- Frame assembly on the slides is not included in this project.
- Gutter covers do not need to be repainted. They shall be removed to allow access to the gutters for painting and replaced after painting.
- Vulkem 116 and 171 are acceptable alternates for the caulk specified in the bid documents. Contractor shall state on bid submittal what product they are using.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 24). The deadline for bid submittal is Wednesday, December 6, 2017 at 3:00pm CST.
