



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Heather Mell, Purchasing Agent
Bid: Spray Foam Insulation (Bid #PUR1017-078); Dated: November 13, 2017
Subject: Addendum #1 (1 page)
Date: November 17, 2017

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Notes from the Pre-Bid Meeting:

- Building has 16-foot side walls
- Approximate building dimensions is 125' x 60'; 5,920 square feet
- City will move all items away from the walls about 6-8 feet.
- City will cover evidence with plastic to prevent overspray from getting on anything.
- Ignition barrier is required for the project.
- Contractors shall provide pricing for an option of Retrofit Metal Building Insulation using 3" R10 with WMP 10 vinyl facing.
- Contractor shall use spray foam to insulate the overhead doors regardless of the option chosen at time of award.
- Contractors shall use the Revised Attachment C to submit their bid.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 7). The deadline for bid submittal is Wednesday, November 22, 2017 at 3:00pm CST.
