



ADDENDUM #1

To: All Companies Interested in Submitting a Proposal
From: Rebecca Johnson, CPPB, Purchasing Agent
RFP: Traffic Signal Battery Backup Systems (RFP #PUR0218-136); Dated: March 2, 2018
Subject: Addendum #1 (1 page)
Date: March 8, 2018

The following questions and/or clarifications were asked relative to the above-listed Request for Proposal. This memo is sent for clarification to all companies to whom the RFP was sent.

Question: What length of full intersection run time is required?

Answer: There is no specified run time. The specification is for total battery capacity of 2500 watt/hour. The battery backup systems will be installed at various signal locations with different power usage. The City anticipates getting a full run time of 4 to 8 hours.

Question: What length of flash is required?

Answer: This City does not use flash during battery backup.

The Purchasing Services Division will accept written questions regarding the Request for Proposal until 3:00 p.m. CDT on Tuesday, March 20, 2018. Fax (888) 815-3659 or e-mail (r.johnson2@cedar-rapids.org) all questions to Rebecca Johnson. Any and all questions will be responded to in the form of written addenda to all Proposers. All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment C). The deadline for proposal submittal is Thursday, March 29, 2018 before 3:00 p.m. CDT.