



**To:** All Companies Interested in Submitting a Bid  
**From:** Rebecca Johnson, CPPB, Purchasing Agent  
**RFB:** Electrical Service Installation at Noelridge Park (RFB #PUR0318-150);  
Dated: April 6, 2018  
**Subject:** Addendum #2 (1 page)  
**Date:** April 17, 2018

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the RFB was sent.

**Additional Clarifications (in bold):**

4.2.1 REVISED / ADD

At the existing electrical service panel, come out the side of the panel to a 2" LB then down to a junction box, then run **two (2) 1 ¼" pvc conduits** to the existing 4" inter-duct. Contractor shall **either trench or directional bore** conduit **of the two (2) lines** from the electrical panel to the existing inter-duct.

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment C). The deadline for bid submittal is Thursday, April 19, 2018 before 3:00 p.m. CDT.

---