



### **ADDENDUM #1**

**To:** All Companies Interested in Submitting a Bid  
**From:** Rebecca Johnson, CPPB, Purchasing Agent  
**Bid:** Exterior Ledge Sealing at Veterans Memorial Stadium (RFB #PUR0718-002);  
Dated: July 9, 2018  
**Subject:** Addendum #1 (1 page)  
**Date:** July 20, 2018

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the RFB was sent.

#### **Clarifications from pre-bid meeting held July 17, 2018:**

- Exterior ledge sealing was last done in 2007 with no complications
- The scope of this project is sealing only, not replacement of any other material
- Leaking and ice buildup has caused sagging, creating the need to reseal to prevent further leaks
- Work for this project will not affect the front gate so there is no need to schedule around events
- Both the long horizontal joints and perpendicular joints on the ledge shall be sealed

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment C). The deadline for bid submittal is Tuesday, July 31, 2018 before 3:00 p.m. CDT.

---