



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Muench, CPPB, Purchasing Agent
Bid: Lime Sludge Removal NW Water Treatment Plant, #PUR0718-012
 Dated: July 27, 2018
Subject: Addendum #1 (2 pages)
Date: August 3, 2018

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** Does this need to be excavated out or pumped out?
Answer: The lime sludge needs to be excavated. Any water in the storage lagoon accumulating after a rain event would need to be pumped out.
- 2) **Question:** Is this 50,000 tons of wet or dry material?
Answer: The material is primarily considered wet weight.
- 3) **Question:** Can you provide the bid results for the last two times this has been bid?
Answer: 2015 and 2013 results are below.

	Price per Ton
2015 - estimated 50,000 tons	
Wulfekuhle Injection & Pumping	\$12.99
McMurrin Trucking, Inc.	\$14.74
Biosolids Management Group	\$15.36
Watson Service (not awarded due to various reasons)	\$10.78
2013 - estimated 50,000 tons	
McMurrin Trucking, Inc.	\$7.08
Biosolids Management Group	\$8.47
Wulfekuhle Injection & Pumping	\$12.15

- 4) **Question:** Is there a bid bond or any other bond required?
Answer: No bonds are required for this project.
- 5) **Question:** Is it permissible to dispose of the lime sludge at the landfill?
Answer: Yes, with prior approval.
- 6) **Question:** Will the landfill charge us for the sludge?
Answer: Yes.
- 7) **Question:** Has the sludge been tested?
Answer: Yes - see attached analytical report.
- 8) **Information:** Attached is the analytical report for the lime.
- 9) **Clarification:** Item 4.3.2 b), Page 9: A Beneficial Use Designation does not have to be in place in order to submit a bid, but there must be a high probability that a BUD would be

approved. If you are going to utilize a site with a BUD, please include the name and location of the site, whether there is an active BUD for the site and any other pertinent information with your bid submittal for the City to evaluate.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed bids is Thursday, August 16, 2018, before 3:00 pm CDT at the Office of the City Clerk, 101 First Street SE, Cedar Rapids, IA 52401.