



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Heather Mell, Purchasing Agent
Bid: Erosion Control and Decking Replacement Project (Bid #PUR0718-016; 314348);
Dated: August 15, 2018
Subject: Addendum #1 (1 page)
Date: August 24, 2018

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Notes from the Pre-Bid Meeting:

- Contractor shall provide a barrier around the construction area
- August 31, 2018 is the last game, Partial access can be granted to the area for work around the schedule until October 3, 2018 when full access to the area can be given.
- Back stairway behind deck is included in the project. Existing railing shall be reused.
- Contractor shall fill in under deck up to within a couple inches of concrete.
- Contractor shall remove and reinstall existing fence to access area under deck.
- ADA stair warning strips shall be reused. If any are damaged in removal, Contractor is responsible for replacement.
- Permitting is required for this project and is the responsibility of the Contractor.

Question: Will re-inspection be required after the new deck is installed?

Answer: Yes, the project shall comply with code after changes are made at the time of inspection or they will not be passed.

1011.5.2 Riser height and tread depth. Stair riser heights shall be 7 inches (178 mm) maximum and 4 inches (102 mm) minimum. Rectangular tread depths shall be 11 inches (279 mm) minimum measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's nosing.

1011.5.4 Dimensional uniformity. Stair treads and risers shall be of uniform size and shape. The tolerance between the largest and smallest riser height or between the largest and smallest tread depth shall not exceed 3/8 inch (9.5mm) in any flight of stairs. The greatest winder tread depth at the walkline within any flight of stairs shall not exceed the smallest by more than 3/8 inch (9.5 mm).

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 23). The deadline for bid submittal is Wednesday, September 5, 2018 at 11:00am CDT.