



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Allison Millikin, Purchasing Agent
Bid: Concrete Replacement at Fire Station #9 (Bid #PUR1018-075);
Dated: October 24, 2018
Subject: Addendum #1 (2 pages)
Date: October 31, 2018

The following questions and/or clarifications were asked relative to the above-listed Request for Bid during the Pre-Bid Meeting. This memo is sent for clarification to all companies to whom the bid was sent.

Change:

Scope of Work: Section 4.2.6 – The 2'x2' section of approach has been removed from the Scope of Work. The 12'x12' section of approach has been changed to a 13'x12' section.

Notes from Pre-Bid Meeting:

- There are not any plans or drawings for this bid. Contractor shall refer to the Scope of Work and Specifications.
- The sidewalk being replaced is located on the North side of the Fire Station in front of the building along the right of way. The sidewalk shall be replaced from the new existing concrete on the corner of Broderick Drive NE and C Ave NE to the marked spot on the West side of the Fire Station driveway.
- The sidewalk in driveway shall be 5 feet wide and be 8-inch thickness. The sidewalk width outside of the driveway shall match the existing sidewalk width and be 4-inch thickness.
- Contractors shall use 2-day turnaround mix for the sidewalk in the driveway.
- No caulk is required between joints. The expansion joints do not need caulk. Please place expansion joint materials as close to grade as possible. Do not recess more than ¼".

Question: Are we able to use fiberglass rebar in place of steel rebar?

Answer: The City would like steel rebar.

Question: Do you have a current planholders list for this project?

Answer: Please see list of Vendors below.

All American Concrete
Anne Duffield Construction
Atwater Concrete
Barnes Grading & Construction
Bernet Construction Company
C&C Construction
Carl A. Nelson & Company
Central States Concrete
Citywide Construction Corp.
Coberly Concrete

Connerley Construction
Curtis Contracting
D&D Superior Concrete Construction
DC Concrete, Inc.
E&F Paving Company
Earthworks Concrete
Eastern Iowa Excavating & Concrete
Eastern Iowa Sprayfoam & Waterproof
Kelly Concrete Co.
Midwest Concrete

Mid States Rebar and Supply
Pacos Construction
Poured Walls of Iowa, Inc.
Price Properties LLC
Quality Construction Services, Inc
Rathje Construction
Rex Concrete, Inc.
River City Cutting & Coring

Roger's Concrete Construction
S&H Concrete, LLC
Swift & Swift LLC
Taylor Construction
Technical Specialty Systems
Vector Construction, Inc.
Weidner Construction
Wirtanen Concrete

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 23). The deadline for bid submittal is Wednesday, November 7, 2018 at 3:00pm CST.