



### **ADDENDUM #1**

**To:** All Companies Interested in Submitting a Bid  
**From:** Ann Harris, Purchasing Agent  
**Bid:** Flow Control Valves (RFB#PUR0419-226); Dated: 04/26/19  
**Subject:** Addendum #1 (1 page)  
**Date:** 05/02/19

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

**Question:** What type of voltage is needed for the Badger meter? 120vac or 24 vdc?

**Answer:** 24 VDC

---

The Purchasing Services Division will accept written questions regarding the bid until 3:00pm CDT on Wednesday, May 1, 2019. Fax (888) 815-3659 or e-mail [a.harris@cedar-rapids.org](mailto:a.harris@cedar-rapids.org) all questions to Ann Harris. Any and all questions will be responded to in the form of written addenda to all Bidders. All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 11). The deadline for bid submittal is Date at 3:00pm CDT.