



### **ADDENDUM #1**

**To:** All Companies Interested in Submitting a Bid  
**From:** Heather Mell, Purchasing Agent  
**Bid:** Caulking & Painting Noelridge Pool (Bid #PUR0719-018); Dated: August 5, 2019  
**Subject:** Addendum #1 (1 page)  
**Date:** August 9, 2019

---

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

#### **Notes from Pre-Bid Meeting:**

- Contract will be able to begin the project on September 9, 2019.
- Tnemec Series 161 will also be accepted.
- Expansion joint around the pool basin is included with the pool basin cost.
- Gutter covers shall be removed to paint the gutter trough and replaced. Gutter covers do not need to be painted.
- Paint lines shall be painted for the depth of the pool
  - Green line at 1' level
  - Yellow line at 2' level
  - Red line at 3' level
  - All other lines shall be painted black

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 22). The deadline for bid submittal is Friday, August 16, 2019 at 3:00pm CDT.

---