



To: All Companies Interested in Submitting a Bid
From: Rebecca Johnson, CPPB, Purchasing Agent
RFB: Liebert HVAC Unit & Upgraded Controller (RFB #PUR0719-020); Dated: Aug. 1, 2019
Subject: Addendum #1 (1 page)
Date: August 12, 2019

The following questions and/or clarifications were asked relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the RFB was sent.

Clarifications from pre-bid meeting held on Wednesday, August 7, 2019:

- The two existing units cannot be shut down
- The purpose of the new unit is to provide redundancy as back up for the two existing units
- No wall penetration will be necessary in the data room
- Contractor can pull from existing duct work

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment C). The deadline for bid submittal is Thursday, August 15, 2019 before 3:00 p.m. CDT.