



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Rebecca Johnson, CPPB, Purchasing Agent
Bid: Asphalt Project at Twin Pines; Dated: August 21, 2009
Subject: Addendum #1 (1 page)
Date: August 25, 2009

The following question and/or clarifications were asked by a bidder relative to the above-listed Request for Bid. This memo is sent for clarification to all companies to whom the bid was sent.

Clarifications from pre-bid meeting held August 25, 2009 at 10:00 a.m.:

- The bid document states three-inch (3") depth for both the new paving and the overlay. Three inches (3") is correct for the new paving but not for the overlay. Only a two-inch (2") depth is required for the overlay.
- Openings will be made in the fence around the golf cart area that will be large enough to accommodate contractor's equipment.
- Cement parking bumpers and plastic storage bins will be removed from the work area.
- Fencing by the bike rack area will be removed to provide access.
- Work must be completed this fall before cold weather becomes an issue.

The Purchasing Services Division will accept written questions regarding the bid until 11:00 a.m. CDT on Thursday, August 27, 2009. Fax (319) 286-5130 or e-mail (r.johnson2@cedar-rapids.org) all questions to Rebecca Johnson. Any and all questions will be responded to in the form of written addenda to all Bidders. All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 8). The deadline for bids is Tuesday, September 1, 2009 at 11:00 a.m. CDT.
