



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Rodenkirk, Purchasing Agent
Bid: WPC Elevator Repairs, Dated: July 23, 2009
Subject: Addendum #1 (1 page)
Date: August 5, 2009

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **NOTE:** The bid due deadline has been changed to **Thursday, August 27, 2009 at 11:00 am CDT**. It is still a sealed bid; bids must be received, date and time stamped at City Hall, 5831 River Ridge Drive NE, Cedar Rapids, no later than 11:00 am on Thursday, August 27, 2009.
- 2) **Change:** Quality elevator product pit flood alarm PFA2 is an approved substitute for Pumpbiz alarm that was specified in the bid document.
- 3) **Clarification:** The decontamination line is marked in the elevator shaft.
- 4) **Informational:** Contractor can rent 4-gas gas monitors from Hawkeye Safety or any other supplier of their choice.
- 5) **Informational:** Contractor is responsible for selecting its own choice for electrical subcontractor. The City does not endorse any electrical company. Known companies who are currently working at the Water Pollution Control Facility are Nelson Electric and ESCO Electric.
- 6) **Clarification:** Contractor is responsible for knowing OSHA confined space rules and must follow those rules on this project.
- 7) **Clarification:** Contractor shall utilize their own safety procedures and shall provide those procedures to WPC staff upon request.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 8). The deadline for sealed bids is Thursday, August 27, 2009, at 11:00 am CDT at the Office of the City Clerk.