



## ADDENDUM #1

**To:** All Companies Interested in Submitting a Bid  
**From:** Rebecca Johnson, CPPB, Purchasing Agent  
**Bid:** Furnace Replacement (Bid #0709-007); Dated: July 18, 2009  
**Subject:** Addendum #1 (1 page)  
**Date:** July 31, 2009

---

This memo is sent for clarification to all companies to whom the bid was sent.

**The revised scope below and the attached drawing (Attachment A) reflect issues discussed at the pre-bid meeting held on Wednesday, July 29, 2009. This revised scope replaces the original scope of work provided on page 3 of the Request for Bid document.**

Remove existing furnace and install new horizontal flow Two Stage Furnace. Minimum specifications are as follows:

- Minimum 92% AFUE rating – (70,000-90,000 BTUs)
- Furnace to be installed as high as possible to avoid future damage from flooding
- New ductwork to be installed in main floor room, overhead (See Print)
- Install 6 high velocity grills to allow for adequate air flow. (See Print)
- Existing in floor ducts need to be removed as much as possible and sealed (concrete caps)
- Reconnect returns and any other duct work still in use

Pricing shall include, but not necessarily be limited to: System sizing, any sheet metal work required to complete installation, flue connections, electrical connections, gas lines, and any other labor and materials required to complete the project.

The City will take care of incidentals such as ceiling and drywall repair.

---

The Purchasing Services Division will accept written questions regarding the bid until 2:30 p.m. CDT on Monday, August 3, 2009. Fax (319) 286-5130 or e-mail (r.johnson2@cedar-rapids.org) all questions to Rebecca Johnson. Any and all questions will be responded to in the form of written addenda to all Bidders. All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 9). The deadline for bid submittal is Thursday, August 6, 2009 at 2:30 p.m. CDT.