



## ADDENDUM #2

**To:** All Companies Interested in Submitting a Bid  
**From:** Diane Rodenkirk, Purchasing Agent  
**Bid:** Generator Rental, Dated: May 20, 2009  
**Subject:** Addendum #2 (1 page)  
**Date:** May 26, 2009

---

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** The specifications indicate the City wants a dual voltage generator. Is that to produce both voltages at the same time or a dedicated voltage of 480 or 208 at any given time?  
**Answer:** The generator shall be a single voltage generator at 480 3-phase output. Dual voltage is not needed. Facility transformers reduce voltage where needed for each distributed voltage rating.

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 8). The deadline for sealed bids is Friday, May 29, 2009, at 2:30 pm CDT at City Hall.