



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Rodenkirk, Purchasing Agent
Bid: 3rd Avenue Parkade HVAC Installation, Dated: September 2, 2009
Subject: Addendum #1 (1 page)
Date: September 10, 2009

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Clarification:** The location of this project is the 3rd Avenue Skywalk between 2nd and 3rd Streets SE not the 3rd Avenue Parkade.
- 2) **Change:** The HVAC unit specified in the bid document is being phased out by the manufacturer. The unit should be Carrier 50TC-A07A2A5-0A0A0 – see information identified as Attachment B.
- 3) **Clarification:** Contractor is responsible for all traffic control and providing their own equipment to reach the top of the skywalk.
- 4) **Clarification:** Contractor will be responsible to pay all permit fees.
- 5) **Clarification:** Contractor will do all hard wiring and internal wiring on the unit. The City will install all controls and thermostat.
- 6) **Clarification:** The power source for the HVAC unit is on the 2nd floor of the building near the skywalk entrance.
- 7) **Clarification:** No economizer or low ambient control is necessary for this project.
- 8) **Question:** What was the plan for fall protection? Is there a place that we can put up cables and anchors?
Answer: Be it stanchions or temporary anchors for fall protection that is the responsibility of the vendor. Any anchoring must be repaired back to original when done.

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 8). The deadline for sealed bids is Wednesday, September 16, 2009, at 11:00 am CDT at the Office of the City Clerk.