



ADDENDUM #1

To: All Companies Interested in Submitting a Bid
From: Diane Rodenkirk, Purchasing Agent
Bid: Liquid Carbon Dioxide, Bid #1009-084; Dated: October 12, 2009
Subject: Addendum #1 (1 page)
Date: October 15, 2009

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** Vendor purchases carbon dioxide for resale from Plant and the product is NSF certified. The Plant will be the primary supply point. Vendor will be the end supplier, but Plant will be NSF certified. Does this create a problem with the NSF compliance section of the bid that states the certification listing the name of end supplier?
Answer: The end result for NSF/ANSI 60 compliance is that the manufacturer of the carbon dioxide is certified and end supplier shows proof of that upon delivery by providing a Certificate of Compliance/Analysis at delivery. The intent of end product specification is the end supplier meets or exceeds established quality standards.

The Certificate of Compliance/Analysis should include the following as a minimum:

- a. Issued to (J Avenue Water Treatment Plant or Northwest Water Treatment Plant)
- b. Issued by
- c. Date of analysis
- d. Shipping order
- e. Tractor/trailer #
- f. Bill of lading
- g. Batch number
- h. Test parameter
- i. Specification
- j. Result
- k. Analysis performed by

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (page 11). The deadline for sealed bids is Thursday, October 22, 2009, at 2:30 pm CDT at the Office of the City Clerk.