

Addendum 1

Drawings

Sheet AD101

1. Change note 6 to read: Existing storage cabinets to be removed
2. Storage unit located at the left end of the stair in the storage room to remain.
3. All existing VCT to remain. Provide allowance of \$1.75 sq ft for new carpet and VCT.
4. Remove trim around existing window in the exterior East wall of the storage room.

Sheet A101

1. Add panic hardware to all exterior doors
2. Locate 1 fire extinguisher within 5'-0" of each exterior door
3. Use abuse resistant drywall in the (2) Interview Rooms
4. Community Room -add note 5 and 6 to opening created from storage cabinets being removed
5. Cover window in Interview Room #2/Storage with plywood and abuse resistant drywall. Finish face of drywall to match face of existing wall.

Sheet A401

1. 10/A401: The width of the glass and door is 22'-6".
2. Water closet: Kohler Highcliff K-4368 with a Royal Model Flushometer 111 and Bemis plastic seat 1955SSC
3. Urinal: Kohler Bardon Superior K-4960-ET with a Royal Model Flushometer 186-1.0
4. Lavatory: Kohler K-2196-1N-0
5. High-Low Drinking Fountain: Elkay model EZSTLC
6. Partition walls to be plastic laminated particle board