



## ADDENDUM #2

**To:** All Companies Interested in Submitting a Proposal  
**From:** Diane Muench, CPPB, Purchasing Services Manager  
**Proposal:** Fire Station Alerting System, RFP #PUR0619-264; Dated: August 12, 2019  
**Subject:** Addendum #2 (1 page)  
**Date:** August 22, 2019

---

Please note the following specification changes/additions/clarifications relative to the above Request for Bid.

- 1) **Question:** Does the city have a permanent VPN solution in place?  
**Answer:** Yes. NetMotion is typically used for mobile data computers. Dell (Aventail) is used for City domain access.
- 2) **Question:** Does the radio system have Type 1 or Type 2 vocoders on the P25 radio system?  
**Answer:** Currently the City of Cedar Rapids segment of our Harris P25 800MHz trunking radio system is all Phase 1 or FDMA. There are segments of the Harris system that are Phase 2 TDMA.
- 3) **Question:** Please provide the contact information for the City's Hexagon representative.  
**Answer:** Seth Wold, [seth.wold@hexagon.com](mailto:seth.wold@hexagon.com), 435-618-9009
- 4) **Question:** Please provide the make and model for each UPS.  
**Answer:** Central Fire – Emerson Liebert APM 30kVA 208V-60Hz-APM; Stations 2-9 – Tripplite SM2200RMXL2UTAA
- 5) **Question:** Upon how many talk groups does the City want the automatic voice to be voiced.  
**Answer:** Only one total talkgroup.

---

All addenda that you receive shall become a part of the contract documents and shall be acknowledged and dated on the bottom of the Signature Page (Attachment B). The deadline for sealed proposals is Friday, September 13, 2019, before 3:00 pm CDT at the Purchasing Services Division, 101 First Street SE, Cedar Rapids, IA 52401.